W-4412 - DELOITTE HASKINS & SELLS -
1 WTC - 97th FLOOR - DEMOLITION OF
EXISTING OFFICE SPACE

WTC1-50-P

W-4412

REVIEW STATUS

Sub-mission#	Response To #	Coordi-nator	TCRU Memo	Approval	Facility Rider	Outstanding Comments	Remarks
1(11.12.89)	—	FD-B	11-16-89	✓		1	

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

M E M O R A N D U M

To: Mr. A. Vaccaro, Acting General Manager,
Planning, Design & Construction, WT&ED
From: Ennala Ramabhushanam
Date: November 16, 1989
Subject: **WTC - ALTERATION APPLICATION #W-4412 - DELOITTE, HASKINS, & SELLS - 1 WTC, 97TH FLOOR - DEMOLITION OF EXISTING OFFICE SPACE**

Reference: Review Request dated 11/2/89

Copy To: T. O'Connor L. Menno Job Folder
R. Wegel Chrono Folder

A review of the material submitted with the referenced request for the subject application has been made.

It is recommended that approval to proceed with construction be given subject to the submission of the items listed below being revised in accordance with the one (1) requirement listed on the attached rider.

Drawings:

REMARKS: 1) Following drawings are recommended for approval.

D-1	issued	10/30/89
D-2	issued	10/30/89
H97-D-1	undated	

2) This memorandum was transmitted to the Facility via OA on November 16, 1989.

for V. Donlon

Ennala Ramabhushanam, P.E.
Manager
Quality Assurance Division

FD-B/dm
att.

RIDER

ALTERATION APPLICATION #V-4412

HVAC

1. Dwg. H97-D-1, Demolition Note NO. 15. Revise last paragraph of the note to require that air filters shall either be Class 1 or Class 2. See N.Y.C. Building Code, RS 13-1, Section 2-4.1.1.

111689

1/3

TENANT ALTERATION REVIEW REQUEST

X	CHECK APPLICABLE ROUTING	ROOM NO.
✓	C.P. COOPER	
✓	QUALITY ASSURANCE REV.	51-N
✓	C. SEMAH	74-5
✓	G. DALY	74-5
✓	M. GLAVICIC	74-5

Description of Work:

DEMOLITION OF EXISTING OFFICE SPACE.
Work includes - Demo - of Arch. Partitions, Elec, Tele, Ceiling & H.V.A.C.

W

FACILITY: ONE WTC
APPLICANT'S NAME: DELOITTE HASKIT
APPLICATION NO.: W - 4412
DRAWING NO(S).: 3
DATE: 11 12 89

___ You are requested to review the attached applications and forward your comments to:

___ Attached are revised drawings. Please review

Org. Unit	Contact	Rm. No.	Ext.
	Joseph Ruiz	745	466 8668

NOT LATER THAN: 10-20-89

Title: Arch/DESIGNER

If no reply is received by above date, your concurrence will be assumed unless arrangements have been made for additional time.

DELOITTE, HASKINS & SELLS
TAA# 4412, Contract # WTC-591.861

DWG NAME		DATE
D-1	Partition/Elec. & Telep. Demo PL.	10/30/89
D-2	Reflected Ceiling Demo. PL.	10/30/89
H97-D-1	HVAC DEMO. Plan	10/31/89

THE PORT AUTHORITY OF N.Y. & N.J.
TENANT CONSTRUCTION REVIEW UNIT
RECEIVED
NOV 03 1989
ALTERATION APPLICATION

Office copy

W-4412 (1)

cc: J. Napolitano, L. Menno,

Estimated Price $257,000

Signature	Title	Date
Joseph Napolitano for L. Menno		